



MIN SLOPE 1/4" PER FT 4" PIPE
 MIN SLOPE 1/8" PER FT 6" PIPE

4" OR 6" PIPE

4" OR 6" PIPE

STONE BEDDING

NOTE:
 THE ENTIRE INSTALLATION MUST BE INSPECTED
 AND APPROVED BY THE W.E.W.J.A. REPRESENTATIVE
 PRIOR TO BEING BACKFILLED

SERVICE CONNECTION TO
 SANITARY SEWER FOR
 A NEW INSTALLATION

Washington-East Washington Joint Authority

Scale: NONE	Drawn By: RLK	Approved: QJK	Drawing No.
Date: 10-83	Checked by: TGS		SD-2